

GENERAL NOTES

PROJECT NOTES

1. ALL EXISTING PIPE SHALL BE RETAINED UNLESS OTHERWISE NOTED.
2. A NOTICE OF INTENT (NOI) IS NOT REQUIRED FOR THIS PROJECT.
3. THE CONTRACTOR SHALL NOT DISTURB MORE THAN ONE ACRE OF THE ENTIRE PROJECT.
4. THE ELEVATIONS SHOWN ON THE DRAINAGE PROFILE AND DRAINAGE MAP ARE BASED ON ASSUMED EVELATIONS. THEY DO NOT MATCH TRUE FEILD ELEVATIONS.
5. CONTRACTOR SHALL STABILIZE ALL DISTRUBED AREAS WITHIN 24 HOURS OF THE DISTRUBANCE.

UTILITY OWNER	SERVICE
GEORGIA POWER COMPANY DISTRIBUTION	ELECTRICAL
COMCAST	CABLE TV
ATLANTA GAS LIGHT COMPANY	GAS
CITY OF ATLANTA BUREAU OF DRINKING WATER	WATER
BELLSOUTH TELECOMMUNICATIONS, INC. D/B/A	TELEPHONE
CITY OF ATLANTA WATERSHED MANAGEMENT	SEWER
FULTON COUNTY PUBLIC WORKS	SEWER



**Know what's below.
Call before you dig.**

SPECIAL NOTES:

1. THE CONTRACTOR SHALL REMOVE ALL SILT AND DEBRIS FROM EXISTING DRAINAGE STRUCTURES THAT FALL WITHIN CONSTRUCTION LIMITS. PIPES AND CULVERTS THAT ARE RETAINED SHALL BE CLEANED BEFORE ANY WORK BEGINS AND AT THE COMPLETION OF THE PROJECT. THE COST OF THIS WORK SHALL BE INCLUDED IN THE BID PRICE FOR GRADING COMPLETE.
2. THE COST FOR SAW CUTS, REMOVAL AND DISPOSAL OF EXISTING SHOULDER MATERIAL, PIPE, MINOR DRAINAGE STRUCTURES, EXISTING HEADWALLS AND GUARDRAIL SHALL BE INCLUDED IN THE BID PRICE FOR GRADING COMPLETE.
3. ALL BORROW PITS, WASTE AND STOCKPILE SITES SHALL BE ENVIRONMENTALLY APPROVED PRIOR TO USE.
4. ALL REMOVED MATERIALS SHALL BE DISPOSED IN AN AREA DEEMED SUITABLE BY THE GEORGIA DEPARTMENT OF TRANSPORTATION.

TYPE OF PIPE INSTALLATION		CORRUGATED STEEL AASHTO M-36		CORRU-GATED ALUMINUM AASHTO M-196	PLASTIC				
		ALUMINUM COATED (TYPE 2) CORR. STEEL	PLAIN ZINC COATED	PLAIN UNCOATED ALUMINUM	CORR. POLY-ETHYLENE AASHTO M-252	CORR. POLY-ETHYLENE SMOOTH LINED AASHTO M-294 TYPE "S"	POLY VINYL CHLORIDE (PVC) PROFILE WALL AASHTO M-304	POLY VINYL CHLORIDE (PVC) CORR. SMOOTH INTERIOR ASTM F-949	
STORM DRAIN	LONGITUDINAL INTERSTATE AND TRAVEL BEARING	X							
	LONGITUDINAL NON-INTERSTATE AND NON-TRAVEL BEARING	X				X	X	X	
	GRADE ≤ 10%	ADT < 250	X				X	X	X
		250 < ADT < 1500	X				X	X	X
		1500 < ADT < 15000	X				X	X	X
	GRADE > 10%	ADT < 250					X	X	X
		ADT > 250					X	X	X
	SIDE DRAIN		X				X	X	X
PERMANENT SLOPE DRAIN			X	X	X	X	X	X	
PERFORATED UNDERDRAIN			X	X	X	X		X	

* THIS TYPE PIPE CAN BE USED IF THE ADDITION OF TYPE "B" COATING (AASHTO M-190, HALF BITUMINOUS COATED WITH PAVED INVERT) IS UTILIZED.

NOTE:

1. ALLOWABLE MATERIALS ARE INDICATED BY AN "X".
2. STRUCTURAL REQUIREMENTS OF STORM DRAIN PIPE WILL BE IN ACCORDANCE WITH GEORGIA STANDARD 1030-D OR 1030-P, WHICHEVER IS APPLICABLE, AND THE STANDARD SPECIFICATIONS.
3. GRADED AGGREGATE BACKFILL SHALL BE USED IN CROSS DRAIN APPLICATIONS FOR ALL PLASTIC PIPES. (AASHTO M-294, HDPE PIPE, ASSHTO M-304, PVC PIPE, ASTM F-949, PVC PIPE)
4. THE CONTRACTOR SHALL PROVIDE ADDITIONAL STORM SEWER CAPACITY CALCULATIONS IF A PIPE MATERIAL OTHER THAN CONCRETE IS SELECTED.

3/1/2007 GPLN
 0009630GN02.dgn (REV) DWG 1-43
 0009630GN02.dwg (REV) DWG 1-43
 0009630GN02.dwg (REV) DWG 1-43
 0009630GN02.dwg (REV) DWG 1-43

GEORGIA
 DEPARTMENT
 OF
 TRANSPORTATION

REVISION DATES

10/11/2010		

STATE OF GEORGIA
 DEPARTMENT OF TRANSPORTATION
 OFFICE: TRAFFIC OPERATIONS

GENERAL NOTES

SR6/ CAMPCREEK PARKWAY
 FULTON COUNTY

DRAWING No.
4-001