

GENERAL NOTES

1. ASPHALT AND CONCRETE DRIVES TO BE REPLACED IN KIND. AGGREGATE OR EARTH DRIVES TO BE PAVED TO THE RIGHT OF WAY OR TIE-IN POINT WITH MATERIAL SHOWN ON CONSTRUCTION PLAN SHEETS. DRIVES SHALL BE PAVED AS FOLLOWS:

ASPHALT DRIVES	RESIDENTIAL:	135 LBS/YD ² ASPHALTIC CONCRETE 9.5 mm SUPERPAVE 6" GRADED AGGREGATE
	COMMERCIAL:	135 LBS/YD ² ASPHALTIC CONCRETE 9.5 mm SUPERPAVE 220 LBS/YD ² ASPHALTIC CONCRETE 19.0 mm SUPERPAVE 6" GRADED AGGREGATE
CONCRETE DRIVES	RESIDENTIAL:	6" CONCRETE, 4" GRADED AGGREGATE
	COMMERCIAL:	8" CONCRETE, 6" GRADED AGGREGATE

2. UTILITY OWNERS:

NAME OF UTILITY OWNER	UTILITY
ATLANTA GAS LIGHT COMPANY	NATURAL GAS
FORSYTH COUNTY WATER DEPARTMENT	WATER
BELLSOUTH TELECOMMUNICATIONS	TELEPHONE
SAWNEE EMC	ELECTRIC

3. THE ATTENTION OF THE CONTRACTOR IS SPECIFICALLY DIRECTED TO THE UTILITY CONFLICTS SPECIAL PROVISION REQUIRING PROTECTION OF UTILITY INSTALLATIONS WHICH MAY EXIST ON THE PROJECT. UNDERGROUND UTILITY LOCATIONS CAN BE OBTAINED BY CALLING THE UPC'S ONE CALL CENTER AT 1-800-282-7411.

4. ALL EXISTING DRAINAGE PIPE NOT TO REMAIN FOR PROPOSED DRAINAGE PURPOSES SHALL BE REMOVED. COST FOR REMOVAL TO BE INCLUDED IN PRICE BID FOR GRADING COMPLETE.

5. AN NOI FOR STORM WATER DISCHARGE IS REQUIRED FOR THIS PROJECT.

ROADWAY LEGEND

	EXISTING	PROPOSED
RIGHT-OF-WAY	---	---
REQUIRED RIGHT-OF-WAY MARKER		☒
CENTERLINE	+	+
DITCH OR SWALE	----	----
TYP. SECTION DITCH		→
TOP OF CUT		-C-
TOE OF FILL		-F-
PROPERTY LINE	---	---
EASEMENT FOR CONSTR. OF DRIVES		▨
EASEMENT FOR CONSTRUCTION OF SLOPES		▨
PAVEMENT OVERLAY		▨
ASPHALT PAVEMENT OBLITERATION		▨
STRAIN POLE		⊙

TYPE OF PIPE INSTALLATION	CONCRETE	CORRUGATED STEEL AASHTO M-36		CORRU-GATED ALUMINUM AASHTO M-196	PLASTIC		
		ALUMINUM COATED (TYPE 2) CORR. STEEL	PLAIN ZINC COATED	PLAIN UNCOATED ALUMINUM	CORR. POLY-ETHYLENE AASHTO M-252	CORR. POLY-ETHYLENE SMOOTHED LINED AASHTO M-294 TYPE "S"	POLY VINYL CHLORIDE (PVC) PROFILE WALL AASHTO M-304
LONGITUDINAL INTERSTATE AND TRAVEL BEARING	X						
LONGITUDINAL NON INTERSTATE AND NON TRAVEL BEARING	X	X		X		X	X
STORM DRAIN	GRADE < 10%	ADT < 150	X	X		X	X
		250 < ADT < 1500	X	X*	X		
		ADT > 1500	X				
GRADE > 10%	ADT < 250		X	X		X	X
	ADT > 250			X			
SIDE DRAIN	X	X		X		X	X
PERMANENT SLOPE DRAIN		X	X	X		X	X
PERFORATED UNDERDRAIN		X	X	X	X	X	

* This type pipe can be used if the addition of Type "B" coating (AASHTO M-190, Half Bituminous Coated with Paved Invert) is utilized.

NOTES:

- Allowable materials are indicated by an "X".
- Structural requirements of storm drain pipe will be in accordance with Georgia Standard 1030-D or 1030-P, whichever is applicable, and the Standard Specifications.



GEORGIA DEPARTMENT OF TRANSPORTATION

SR 400/US 19 AT CR 176/SETTINGDOWN ROAD

GENERAL NOTES

DESIGNED: MW	CHECKED: LJH	DATE:	4.01
DRAWN: CEC	JOB NO. 2077-758	SCALE: NO SCALE	SHEET REV

NO.	DATE	DESCRIPTION OF REVISION

THIS LINE IS ONE INCH LONG WHEN PLOTTED FULL SCALE