

# GENERAL NOTES

1. A N. O. I. IS NOT REQUIRED FOR THIS PROJECT.

| UTILITY OWNER     | SERVICE   |
|-------------------|-----------|
| GEORGIA POWER     | POWER     |
| COLONIAL PIPELINE | PETROLEUM |
| GDOT              | CCTV      |

- ALL BORROW AND WASTE SITES FOR THIS PROJECT SHALL BE ENVIRONMENTALLY APPROVED PRIOR TO CONSTRUCTION ACTIVITIES OCCURRING IN THEM. ALL COMMON FILL OR EXCESS MATERIAL DISPOSED OUTSIDE THE PROJECT RIGHT OF WAY SHALL BE PLACED IN EITHER A PERMITTED SOLID WASTE FACILITY, A PERMITTED INERT WASTE LANDFILL OR IN AN ENGINEERED FILL. : SEE SECTION 201 OF THE STANDARD SPECIFICATION AND SUPPLEMENTS THERETO FOR ADDITIONAL INFORMATION.
- THERE IS NO SUITABLE PLACE TO BURY EXISTING DRAINAGE IMPROVEMENTS CONSTRUCTION DEBRIS WITHIN THE PROJECT'S LIMITS. THE CONTRACTOR SHALL PROVIDE AN ENVIRONMENTALLY APPROVED SITE TO DISPOSE OF EXISTING CONSTRUCTION DEBRIS AT NO ADDITIONAL COST TO THE DEPARTMENT.
- REMOVAL OF GUARDRAIL SHALL BE INCLUDED IN OVERALL BID PRICE FOR GRADING COMPLETE.
- TREE REMOVAL AS NOTED IN THE PLANS SHALL BE INCLUDED IN THE BID PRICE FOR GRADING COMPLETE.

NOTES:  
 UTILITY DISCLAIMER: EXISTING UTILITY LINES SHOWN ARE APPROXIMATE LOCATIONS ONLY. THE CONTRACTOR/INSTALLER SHALL FIELD VERIFY ALL EXISTING UTILITY LINE LOCATIONS PRIOR TO ANY CONSTRUCTION. DAMAGE TO EXISTING UTILITY LINES RESULTING FROM THE CONTRACTORS/INSTALLERS NEGLIGENCE SHALL BE REPAIRED AT THE CONTRACTORS/INSTALLERS EXPENSE.  
 CONTRACTOR/INSTALLER SHALL CONTACT UTILITY LOCATOR SERVICE, 811, PRIOR TO ANY CONSTRUCTION.



Know what's below.  
 Call before you dig.

## ENVIRONMENTAL RESOURCE IMPACT TABLE

| Resource Name/Type | Beginning STA | Ending STA | Side | Construction Activity | Permitted Activity | Controlling Criteria | Special Provision? | Comments including any Permit Expiration Dates |
|--------------------|---------------|------------|------|-----------------------|--------------------|----------------------|--------------------|--|
| NONE               |               |            |      |                       |                    |                      |                    |  |

| TYPE OF PIPE INSTALLATION                          | CORRUGATED STEEL AASHTO M-36 | CORRUGATED ALUMINUM AASHTO M-196     |                   | PLASTIC                 |  |  |
|--|------------------------------|--------------------------------------|-------------------|-------------------------|--|--|
|  |                              | ALUMINUM COATED (TYPE 2) CORR. STEEL | PLAIN ZINC COATED | PLAIN UNCOATED ALUMINUM | CORR. POLY-ETHYLENE LINED AASHTO M-252 | CORR. POLY-ETHYLENE SMOOTHED LINED AASHTO M-294 TYPE "S" |
| LONGITUDINAL INTERSTATE AND TRAVEL BEARING         | X                            |                                      |                   |                         |  |  |
| LONGITUDINAL NON-INTERSTATE AND NON-TRAVEL BEARING | X                            | X                                    |                   | X                       | X                                      | X  |
| STORM DRAINS                                       | GRADE ≤ 10%                  | ADT < 250                            | X                 | X                       | X                                      | X  |
|  |                              | 250 < ADT < 1500                     | X                 | X                       | X                                      |  |
|  |                              | ADT > 1500                           | X                 |                         |  |  |
| DRAIN  | GRADE > 10%                  | ADT < 250                            |                   | X                       | X                                      | X  |
|  |                              | ADT > 250                            |                   |                         | X                                      |  |
| SIDE DRAIN   | X                            | X                                    |                   | X                       | X                                      | X  |
| PERMANENT SLOPE DRAIN                              |                              | X                                    | X                 | X                       | X                                      | X  |
| PERFORATED UNDERDRAIN                              |                              | X                                    | X                 | X                       | X                                      |  |

- NOTE:
- ALLOWABLE MATERIALS ARE INDICATED BY AN "X".
  - STRUCTURAL REQUIREMENTS OF STORM DRAIN PIPE WILL BE IN ACCORDANCE WITH GEORGIA STANDARD 1030-D OR 1030-P, WHICHEVER IS APPLICABLE, AND THE STANDARD SPECIFICATIONS.
  - THE CONTRACTOR SHALL PROVIDE ADDITIONAL STORM SEWER CAPACITY CALCULATIONS IF A PIPE MATERIAL OTHER THAN CONCRETE IS SELECTED.



REVISION DATES

|  |  |  |  |
|--|--|--|--|
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |

STATE OF GEORGIA  
 DEPARTMENT OF TRANSPORTATION  
 OFFICE: DESIGN POLICY AND SUPPORT  
**GENERAL NOTES**  
 1-85 SB RAMP TO SR 6 -  
 DRAINAGE IMPROVEMENTS

DRAWING No.  
**4-001**