



TYPE 2-A SIDE BARRIER


RED'D SOIL BEARING CAPACITY	
TYPE	CAPACITY, TONS/SF
2-A	1.25
2-B	1.25
2-C	1.5
2	1.0



TYPE 2-B SIDE BARRIER




TYPE 2-C SIDE BARRIER





TYPE 2


- GENERAL NOTES:
- AT CONTRACTOR'S OPTION, SIDES OF FOOTING KEY MAY BE VERTICAL. MAINTAIN WIDTH SHOWN AT TOP OF KEY. BACKFILL FRONT FACE OF WALL FIRST.
 - UNDERDRAIN SYSTEM PER DETAILS AT BOTTOM LEFT AND/OR NOTE 9 IS REQUIRED FOR TYPES 2-A, 2-B, AND 2-C.
 - EXPOSED CONCRETE SURFACES SHALL RECEIVE A TYPE III FINISH.
 - 1" EXPANSION JOINTS SHALL BE PROVIDED IN WALL, FOOTING AND KEY AT A MAXIMUM SPACING OF 100 FT. EXPANSION JOINTS SHALL BE SPACED UNIFORMLY.
 - CONTRACTION JOINTS SHALL BE AS SPECIFIED FOR SIDE BARRIER, GA. STD. 4948A.
 - EXPANSION AND CONTRACTION JOINTS IN TYPES 2-A, 2-B, AND 2-C SIDE BARRIER SHALL BE WATERPROOFED ON THE BACK SIDE. WATERPROOFING SHALL BE 3-PLY AND EXTEND FROM TOP OF SAND BLANKET TO TOP OF FOOTING FOR 1'-6" MIN. EACH SIDE OF JOINT.
 - TYPES 2, 2-A, 2-B, AND 2-C SIDE BARRIER SHALL BE PAID FOR PER LIN. FT. AS CONCRETE SIDE BARRIER, TYPE 2, 2A, 2B, OR 2C PRICE BID TO INCLUDE COST OF WATERPROOFING AND ALL INCIDENTALS AS SPECIFIED IN SECTION 621 OF THE STD. SPEC.
 - SIDE BARRIER DESIGNED FOR THE FOLLOWING SOIL PROPERTIES:
 θ = ANGLE OF INTERNAL FRICTION 28°
 γ = UNIT WEIGHT = 110 PCF
 μ = COEFF. OF SLIDING FRICTION = .45
 - A SYNTHETIC DRAINAGE BLANKET SELECTED FROM THE DEPARTMENT'S QUALIFIED PRODUCTS LIST IS AN ACCEPTABLE SUBSTITUTE FOR THE SAND BLANKET, BAG OF STONE, AND MESH SCREEN SHOWN IN THE UNDERDRAIN DETAILS.




SEE GEN. NOTE 9 FOR ALTERNATE



Δ (INCHES)	
WALL TYPE	DIMENSION
2-A	0
2-B	0
2-C	3/16



(FOR USE IN FOOTING AND CONTRACTION JOINT) SHEAR KEY DETAIL



WALL BATTER DETAIL

GLO	BY	DES. _____ (SUBMITTED) <i>B.A.A. Ste</i> STATE ROAD & AIRPORT DESIGN ENGINEER	NO SCALE	DEC., 1999
DEPARTMENT OF TRANSPORTATION STATE OF GEORGIA STANDARD CONCRETE SIDE BARRIER TYPES 2, 2A, 2B & 2C				
ADDED BAR LAP NOTE AND WALL BATTER DETAIL.		DATE	NUMBER	
REVISION			4948B	